Certificate of Constancy of Performance

Certificate No.: 0757-CPR-288-9003772-1-3

Basis:
EN 12101-2:2003-06

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Smoke and heat control system (NSHEV)

Product description/ specification	**Lacker NRWG** Profile system: Lacker see ift Product Passport no. 11-003590-PR07
Levels and classes of performance	Requirements fulfilled
Intended use(s)	This NSHEV was tested without side wind influence. Therefore, use of this NSHEV is allowed only in mounting positions without risk caused by exposure to side wind flow i.e. use in side walls. For notes on use refer to product passport No. 11-003590-PR07. Design and dimensions of the NSHEV are subject to the relevant national rules and regulations concerning use and application.
placed on the market under the name or trade mark of	**LACKER GmbH** Schellenbergstr. 1, DE-72178 Waldachtal
and produced in the manufacturing plant(s)	**LACKER GmbH** Schellenbergstr. 1, DE-72178 Waldachtal
Notified body No.	**0757**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 12101-2 : 2003

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the **constancy of performance of the construction product.**

This certificate was first issued on 23.04.2020 and will remain valid until 22.04.2029, as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

The use of this certificate and the marking of the products are bound by an existing certification and surveillance contract with the **ift** Rosenheim no. 288 9003772.

ift Rosenheim GmbH
Theodor-Gietl-Str. 7-9
83026 Rosenheim
Germany
Notified Body 0757

Dr. Gerhard Wackerbauer
Deputy head of the notified product certification body
Certification & Surveillance Body
ift Rosenheim
23.04.2026

www.ec.europa.eu

Identity check

www.ift-rosenheim.de/ift-zertifiziert
ID: 51D-5C81B

Ve-Zer-5122-en / 2024-12